



Fire Underwriters Survey
A SERVICE TO INSURERS AND MUNICIPALITIES

c/o SCM Opta Information Intelligence

October 21st, 2019

RECOGNITION FOR FIRE INSURANCE GRADING RECEIVED

Town of Lincoln

Lincoln Fire Rescue & Emergency Services

Superior Tanker Shuttle Service - Accredited

I am pleased to advise you that the above-mentioned fire protection district within the province of Ontario has been maintained in the fire insurance grading index as being accredited for the delivery of Superior Tanker Shuttle Service.

The requirements for this accreditation are stringent and verify that the fire protection district is capable of delivering the minimum accepted fire flows to detached dwellings throughout the fire protection district and within 8 kilometres (km) by road of the below accredited fire stations. This accreditation is an equivalency to the minimum requirements for hydrant protection, as set out by the insurance industry and Fire Underwriters Survey.

Fire Underwriters Survey has provided information on fire protection and risk levels to the insurance industry in Canada since 1883. Fire Underwriters Survey was previously operated under the auspices of the Insurers Advisory Organization and CGI; however, is now operated by SCM Opta Information Intelligence.

Should you have any questions or concerns related to Fire Underwriters Survey, the Superior Tanker Shuttle Service Accreditation process or any other related area, please contact the offices of Fire Underwriters Survey for further information.

Please note that this accreditation expires on October 21st, 2024 and is valid for the following fire stations:

- Lincoln – Fire Station #1 – 4594 Ontario St., Beamsville, Lincoln, ON LOR 1B3
- Lincoln – Fire Station #2 – 3970 Fly Rd., Campden, Lincoln, ON LOR 1G0
- Lincoln – Fire Station #4 – 3793 Nineteenth St., Jordan Station, Lincoln, ON LOR 1S0

Personal Lines Fire Insurance Classification – DPG 3B(S) – Flow Rate of 203 IGPM

Please contact our office if there are any questions or comments regarding the intent or content found throughout this letter.

Regards,

Shamus Bourton, CFPE
 Public Fire Protection Specialist
 Fire Underwriters Survey

Western Canada 101-8333 Eastlake Drive, Burnaby, BC V5A 4W2 1 (800) 665-5661	Ontario 600-175 Commerce Valley Drive West, Markham, ON L3T 7P6 1 (800) 268-8080	Quebec 1611 Cremazie Boulevard East Montreal, QC H2M 2P2 1 (800) 263-5361	Atlantic Canada 220-30 Damascus Road, Bedford, NS B4A 0C1 1 (877)-634-8564
--	--	---	--